



FIRE FIGHTER I

JPR: FFI-3N

Candidate: _____

STANDARD: 4.3.15 NFPA 1001, 2019 Edition Fire Ground Operations	TASK: Connect a fire department pumper to a water supply as a member of a team, given supply or intake hose, hose tools, and a fire hydrant or static water source, so that connections are tight and water flow is unobstructed.	
PERFORMANCE OUTCOME:	The candidate, while operating as a member of a team, shall demonstrate the ability to hand lay a supply hose, connect and place hard suction hose for drafting operations, deploy portable water tanks as well as the equipment necessary to transfer water between and draft from them, make hydrant-to-pumper hose connections for forward and reverse lays, connect supply hose to a hydrant, and fully open and close the hydrant. Safety: A safety violation is grounds for automatic failure. All proctors present shall review the safety violation.	
Equipment Required: Full PPE, appropriate equipment for hydrant or static water supply.		
Conditions: Given a static water source or fire hydrant, the candidate shall demonstrate the ability to:		
No.	Task Steps	✓
	CHECK: Fire Hydrant <input type="checkbox"/> or Static Water Source <input type="checkbox"/>	
FIRE HYDRANT CONNECTION VIA FORWARD & REVERSE LAY		
1.	Connect supply hose to hydrant.	
2.	Connect supply hose to pumper intake.	
3.	Fully open hydrant.	
4.	Fully close the hydrant.	
STATIC WATER SOURCE		
1.	Deploy portable water tank.	
2.	Check gaskets on the hard suction hose for dirt, gravel or defects.	
3.	Connect strainer to hose.	
4.	Connect hard suction hose to pumper.	
5.	Lower hose and strainer into static water source.	

Evaluator (Print & Sign)

Date:



FIRE FIGHTER I

JPR: FFI-5B

Candidate: _____

<p>STANDARD: 4.5.2 NFPA 1001, 2019 Edition Preparedness, and Maintenance</p>	<p>Task: Clean, inspect, and return fire hose to service, given washing equipment, water, detergent, tools, and replacement gaskets, so that damage is noted and corrected, the hose is clean, and the equipment is placed in a ready state for service.</p>	
<p>PERFORMANCE OUTCOME:</p>	<p>The candidate shall demonstrate the ability to clean different types of hose, operate hose washing and drying equipment (if available), mark defective hose, and replace coupling gaskets, roll hose, and reload hose. Safety: A safety violation is grounds for automatic failure. All proctors present shall review the safety violation.</p>	
<p>Equipment Required: Fire apparatus, scrub brush, hose, cleaning supplies, replacement gaskets, hose washer and dryer (if available), log book or tags for reporting repair needs, and personal protective clothing (proctor to determine what PPE is to be worn).</p>		
<p>CONDITIONS: Given Fire Department hose and apparatus, the candidate shall demonstrate the ability to:</p>		
No.	Task Steps	✓
INSPECT / CLEAN HOSE		
1.	Inspect / Clean hose.	
2.	Inspect / Clean couplings according to department guidelines.	
3.	Dry hose.	
4.	Place in ready state and report any deficiencies.	
RETURNING HOSE TO SERVICE		
5.	Roll hose as selected by proctor (Check one):	
	Straight <input type="checkbox"/> Donut <input type="checkbox"/> Twin Donut <input type="checkbox"/> Self-Locking Twin Donut <input type="checkbox"/>	
6.	Reload hose on apparatus using a hose load specific to apparatus or department:	
	Pre-connect	
	Supply Line	

Evaluator (Print & Sign)

Date: