



FIRE FIGHTER I

JPR: FFI-2A

Candidate: _____

| | | |
|---|---|---|
| <p>STANDARD: 4.2.1</p> <p>NFPA 1001, 2019 Edition</p> <p>Fire Department Communications</p> | <p>Task: Initiate a response to a reported emergency, given the report of an emergency, department SOPs, and communications equipment, so that all necessary information is obtained, communications equipment is operated correctly, and the information is relayed promptly and accurately to the dispatch center.</p> | |
| <p>The candidate shall demonstrate the ability to operate fire department communications equipment, relay information, and record information.</p> | | |
| <p>PERFORMANCE OUTCOME:</p> <p>Safety: A safety violation is grounds for automatic failure. All proctors present shall review the safety violation.</p> | | |
| <p>EQUIPMENT REQUIRED: Department SOP's, communication equipment, paper, and pencil.</p> | | |
| <p>CONDITIONS: Given a scenario of a reported alarm, the candidate shall demonstrate the ability to:</p> | | |
| No. | Task Steps | ✓ |
| 1. | Verbalize how the alarm is received. | |
| 2. | Write proper address and nature of the emergency. | |
| 3. | Promptly contacts dispatch by radio indicating an alarm has been received. | |
| 4. | Informs dispatch that they are responding to the emergency. | |

Evaluator (Print & Sign)

Date:



FIRE FIGHTER I

JPR: FFI-2C

Candidate: _____

| | | |
|---|---|---|
| STANDARD: 4.2.3 NFPA 1001, 2019 Edition Fire Department Communications | Task: Transmit and receive messages via the fire department radio, given a fire department radio and operating procedures, so that the information is accurate, complete, clear, and relayed within the time established by the AHJ. | |
| PERFORMANCE The candidate shall demonstrate the ability to operate radio equipment and discriminate between routine and emergency traffic. | | |
| OUTCOME: Safety: A safety violation is grounds for automatic failure. All proctors present shall review the safety violation. | | |
| EQUIPMENT REQUIRED: Fire department mobile or portable radio. | | |
| CONDITIONS: Given a scenario, the candidate shall demonstrate the ability to: | | |
| No. | Task Steps | ✓ |
| 1. | Determine there is no other radio traffic before transmitting (unless emergency traffic). | |
| 2. | Speak calmly, clearly, distinctly and at a medium speed. | |
| 3. | Transmit a message that is brief, accurate and to the point. | |
| 4. | Identify who the message is addressed to. | |
| 5. | Identify the person or unit transmitting. | |
| 6. | Acknowledges information back from command (if applicable). | |

Evaluator (Print & Sign)

Date:



FIRE FIGHTER I

JPR: FFI-3B

Candidate: _____

| | | |
|--|---|--------------------------|
| STANDARD: 4.3.2 NFPA 1001, 2019 Edition Fire Ground Operations | Task: Respond on an apparatus to an emergency scene, given personal protective clothing and other necessary personal protective equipment, so that the apparatus is correctly mounted and dismounted, seat belts are used while the vehicle is in motion, and other personal protective equipment is correctly used. | |
| PERFORMANCE OUTCOME: | The candidate shall be able to respond safely in a fire department apparatus and to safely dismount at the emergency scene while demonstrating the ability to use each piece of provided safety equipment. Safety: A safety violation is grounds for automatic failure. All proctors present shall review the safety violation. | |
| EQUIPMENT REQUIRED: Fire apparatus, personal protective equipment, hearing protection, eye protection for those not in enclosed cabs. | | |
| CONDITIONS: Given a simulated fire scenario, the candidate shall demonstrate the ability to: | | |
| No. | Task Steps | ✓ |
| MOUNTING: | | |
| 1. | Mount fire apparatus. | <input type="checkbox"/> |
| 2. | Correctly use all protective equipment furnished. | <input type="checkbox"/> |
| DISMOUNTING: | | |
| 3. | Look for hazards before stepping off vehicle. | <input type="checkbox"/> |
| 4. | Safely dismount. | <input type="checkbox"/> |

Evaluator (Print & Sign)

Date:



FIRE FIGHTER I

JPR: FFI-3E

Candidate: _____

| STANDARD: 4.3.5 NFPA 1001, 2019 Edition Fire Ground Operations | Task: Exit a hazardous area as a team, given vision-obscured conditions, so that a safe haven is found before exhausting the air supply, others are not endangered, and the team integrity is maintained. | | | | | | | | | | | | | | | | | | |
|--|--|---|------------|---|----|--|--|----|---|--|----|--|--|----|--|--|----|---|--|
| PERFORMANCE OUTCOME: | The candidate shall demonstrate the ability to operate as a team member in vision-obscured conditions, locate and follow a guideline, conserve air supply, and evaluate areas for hazards and identify a safe haven. Safety: A safety violation is grounds for automatic failure. All proctors present shall review the safety violation. | | | | | | | | | | | | | | | | | | |
| EQUIPMENT REQUIRED: Personal protective equipment, SCBA, hand tools, and hose line / guideline. | | | | | | | | | | | | | | | | | | | |
| CONDITIONS: Given a simulated or live fire scenario, as a member of a team with vision-obscured conditions, the candidate shall demonstrate the ability to: | | | | | | | | | | | | | | | | | | | |
| No. | <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 10%;"></th> <th style="width: 80%; text-align: center;">Task Steps</th> <th style="width: 10%; text-align: center;">✓</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">1.</td> <td>Determine air supply available prior to entering the hazardous atmosphere.</td> <td></td> </tr> <tr> <td style="text-align: center;">2.</td> <td>Monitor the air supply available while in the hazardous atmosphere.</td> <td></td> </tr> <tr> <td style="text-align: center;">3.</td> <td>Locate hose line or guideline and determine correct method of travel for egress.</td> <td></td> </tr> <tr> <td style="text-align: center;">4.</td> <td>Make decision to leave hazardous atmosphere before depletion of air supply while maintaining team integrity.</td> <td></td> </tr> <tr> <td style="text-align: center;">5.</td> <td>Exit hazardous atmosphere before depletion of air supply.</td> <td></td> </tr> </tbody> </table> | | Task Steps | ✓ | 1. | Determine air supply available prior to entering the hazardous atmosphere. | | 2. | Monitor the air supply available while in the hazardous atmosphere. | | 3. | Locate hose line or guideline and determine correct method of travel for egress. | | 4. | Make decision to leave hazardous atmosphere before depletion of air supply while maintaining team integrity. | | 5. | Exit hazardous atmosphere before depletion of air supply. | |
| | Task Steps | ✓ | | | | | | | | | | | | | | | | | |
| 1. | Determine air supply available prior to entering the hazardous atmosphere. | | | | | | | | | | | | | | | | | | |
| 2. | Monitor the air supply available while in the hazardous atmosphere. | | | | | | | | | | | | | | | | | | |
| 3. | Locate hose line or guideline and determine correct method of travel for egress. | | | | | | | | | | | | | | | | | | |
| 4. | Make decision to leave hazardous atmosphere before depletion of air supply while maintaining team integrity. | | | | | | | | | | | | | | | | | | |
| 5. | Exit hazardous atmosphere before depletion of air supply. | | | | | | | | | | | | | | | | | | |

Evaluator (Print & Sign)

Date:



FIRE FIGHTER I

JPR: FFI-3N

Candidate: _____

| | | |
|---|--|---|
| STANDARD: 4.3.15 NFPA 1001, 2019 Edition Fire Ground Operations | TASK: Connect a fire department pumper to a water supply as a member of a team, given supply or intake hose, hose tools, and a fire hydrant or static water source, so that connections are tight and water flow is unobstructed. | |
| PERFORMANCE OUTCOME: | The candidate, while operating as a member of a team, shall demonstrate the ability to hand lay a supply hose, connect and place hard suction hose for drafting operations, deploy portable water tanks as well as the equipment necessary to transfer water between and draft from them, make hydrant-to-pumper hose connections for forward and reverse lays, connect supply hose to a hydrant, and fully open and close the hydrant. Safety: A safety violation is grounds for automatic failure. All proctors present shall review the safety violation. | |
| Equipment Required: Full PPE, appropriate equipment for hydrant or static water supply. | | |
| Conditions: Given a static water source or fire hydrant, the candidate shall demonstrate the ability to: | | |
| No. | Task Steps | ✓ |
| | CHECK: Fire Hydrant <input type="checkbox"/> or Static Water Source <input type="checkbox"/> | |
| FIRE HYDRANT CONNECTION VIA FORWARD & REVERSE LAY | | |
| 1. | Connect supply hose to hydrant. | |
| 2. | Connect supply hose to pumper intake. | |
| 3. | Fully open hydrant. | |
| 4. | Fully close the hydrant. | |
| STATIC WATER SOURCE | | |
| 1. | Deploy portable water tank. | |
| 2. | Check gaskets on the hard suction hose for dirt, gravel or defects. | |
| 3. | Connect strainer to hose. | |
| 4. | Connect hard suction hose to pumper. | |
| 5. | Lower hose and strainer into static water source. | |

Evaluator (Print & Sign)

Date:



FIRE FIGHTER I

JPR: FFI-3Q

Candidate: _____

| | | |
|--|---|--------------------------|
| STANDARD: 4.3.18 NFPA 1001, 2019 Edition Fire Ground Operations | Task: Turn off building utilities, given tools and an assignment, so that the assignment is safely completed. | |
| PERFORMANCE OUTCOME: | The candidate shall demonstrate the ability to identify utility control devices, operate control valves or switches, and assess for related hazards. Safety: A safety violation is grounds for automatic failure. All proctors present shall review the safety violation. | |
| Equipment Required: Personal protective equipment, hand tools for controlling utilities, and utility service boxes. | | |
| CONDITIONS: Given a utility, the candidate shall demonstrate or verbalize the ability to: | | |
| No. | Task Steps | ✓ |
| LOCATE UTILITY SERVICE BOXES | | |
| 1. | Electrical-main panel. | <input type="checkbox"/> |
| 2. | Natural gas-meter or LPG/CNG-storage tank/cylinder. | <input type="checkbox"/> |
| 3. | Water-meter box or building water control valve. | <input type="checkbox"/> |
| SHUT OFF UTILITY | | |
| 1. | Electrical-breaker to “off”. | <input type="checkbox"/> |
| 2. | Natural gas-gas cock to “off” or LPG/CNG-turn valve clockwise to close. | <input type="checkbox"/> |
| 3. | Water-turn valve clockwise to close or water valve cross way to direction of flow. | <input type="checkbox"/> |

Evaluator (Print & Sign)

Date:



FIRE FIGHTER I

JPR: FFI-5A

Candidate: _____

| | | |
|--|---|-----------------------|
| STANDARD: 4.5.1 NFPA 1001, 2019 Edition Preparedness, and Maintenance | Task: Clean and check ladders, ventilation equipment, SCBA, ropes, salvage equipment, and hand tools, given cleaning tools, cleaning supplies, and an assignment, so that equipment is clean and maintained according to manufacturer's or departmental guidelines, maintenance is recorded, and equipment is placed in a ready state or reported otherwise. | |
| PERFORMANCE OUTCOME: | The candidate shall demonstrate the ability to select correct tools for various parts and pieces of equipment, follow guidelines, and complete recording and reporting procedures. Safety: A safety violation is grounds for automatic failure. All proctors present shall review the safety violation. | |
| Equipment Required: Ladders, rope, salvage equipment, ventilation equipment, hand tools, SCBA, service tags, and cleaning supplies. | | |
| CONDITIONS: Given firefighting equipment, the candidate shall demonstrate the ability to: | | |
| No. | Task Steps | ✓ |
| EQUIPMENT TO BE CLEANED AND INSPECTED (SCBA Mandatory & Check One Other): | | |
| SCBA | <input type="checkbox"/> | Hand Tool |
| Ladder | <input type="checkbox"/> | Rope |
| | | Ventilation Equipment |
| | | Salvage Equipment |
| SCBA | | |
| 1. | Inspect / Clean face piece according to department policies. | |
| 2. | Inspect / Clean back plate/frame/harness assembly according to department policies. | |
| 3. | Inspect / Clean cylinder. | |
| 4. | Place in ready state or report any deficiencies. | |
| Hand Tools | | |
| <i>Wooden / Fiberglass Handles:</i> | | |
| 1. | Inspect Handle. | |
| 2. | Inspect Head / Cutting edge / Surface. | |
| 3. | Clean Tool. | |
| 4. | Place in ready state or report any deficiencies. | |



FIRE FIGHTER I

JPR: FFI-Live Fire C

Candidate: _____

| | | |
|---|--|---|
| <p>STANDARD: 4.3.10</p> <p>NFPA 1001, 2019 Edition</p> <p>Fire Ground Operations</p> | <p>Task: Attack an interior below grade level structure fire operating as a member of a team, given an attack line, ladders when needed, personal protective equipment, tools, and an assignment, so that team integrity is maintained, the attack line is deployed for advancement, ladders are correctly placed when used, access is gained into the fire area, effective water application practices are used, the fire is approached correctly, attack techniques facilitate suppression given the level of the fire, hidden fires are located and controlled, the correct body posture is maintained, hazards are recognized and managed, and the fire is brought under control.</p> | |
| <p>PERFORMANCE OUTCOME:</p> | <p>The candidate shall demonstrate the ability to prevent water hammer when shutting down nozzles; open, close, and adjust nozzle flow and patterns; apply water using water using direct, indirect, and combination attacks; advanced charged and uncharged hose line; extend hose line; replace burst hose sections; couple and uncouple various hand line connections; carry hose; and, attack fire at below grade level.</p> <p style="text-align: center;">Safety: A safety violation is grounds for automatic failure. All proctors present shall review the safety violation.</p> | |
| <p>Equipment Required: NFPA 1403 (Standard on Live Fire Training) documentation, full personal protective equipment with SCBA, hose line, hand tools, flashlight, various size ladders, and fire apparatus.</p> | | |
| <p>CONDITIONS: Given an interior below grade level live fire and a team, the candidate shall demonstrate the ability to:</p> | | |
| No. | Task Steps | ✓ |
| 1. | Describe hose line replacement method should hose line burst prior to entry. | |
| 2. | Properly wear full protective clothing and SCBA. | |
| 3. | Properly deploy attack line for advancement to fire. | |
| 4. | Properly bleed attack line and adjust nozzle while preventing water hammer. | |
| 5. | Check door before entering and sound floor for stability. | |
| 6. | Descend stairs safely and quickly using appropriate body posture. | |
| 7. | At bottom of stairs search for and correctly extinguish the fire using pattern selected by proctor. | |
| 8. | Overhaul fire scene while protecting and preserving signs of cause or origin (if present). | |
| <p>CHECK ATTACK PATTERN TO USE FOR FIRE ATTACK:</p> <p style="display: flex; justify-content: space-around;"> DIRECT <input type="checkbox"/> INDIRECT <input type="checkbox"/> COMBINATION <input type="checkbox"/> </p> | | |

Evaluator (Print & Sign)

Date: