



FIRE FIGHTER II

JPR: FFII-5E

Candidate: _____

STANDARD: 5.5.5 NFPA 1001, 2019 Edition Prevention, Preparedness, and Maintenance	Task: Perform an annual service test on fire hose, given a pump, a marking device, pressure gauges, a timer, record sheets, and related equipment, so that procedures are followed, the condition of the hose is evaluated, any damaged hose is removed from service, and the results are recorded.
--	--

PERFORMANCE OUTCOME: The candidate shall demonstrate the ability to operate hose testing equipment, nozzles and to record results.

Safety: A safety violation is grounds for automatic failure. All proctors present shall review the safety violation.

EQUIPMENT REQUIRED: Pump, Marking device, Pressure gauges, Timer, Record sheets, copy of NFPA 1962, and related equipment.

CONDITIONS: Given a fire station bay or large area for testing hose, the candidate shall demonstrate the ability to:

Indicate the method of testing:

Apparatus Pump Hose Testing Machine

No.	Task Steps	✓
1.	Determine the area used for the test is safe.	<input type="checkbox"/>
2.	Follow guidelines for the inspection and testing of fire hose as stated in NFPA 1962 and/or the AHJ.	<input type="checkbox"/>
3.	Identify and remove any damaged section of hose from service per AHJ guidelines.	<input type="checkbox"/>
4.	Record results for each section of hose.	<input type="checkbox"/>

Evaluator (Print & Sign)

Date: