



FIRE FIGHTER I

JPR: FFI-3L

Candidate: _____

STANDARD: 4.3.13 NFPA 1001, 2019 Edition Fire Ground Operations	TASK: Overhaul a fire scene, given full PPE, an attack line, hand tools, a flashlight, and an assignment, so that structural integrity is not compromised, all hidden fires are discovered, fire cause evidence is preserved, and the fire is extinguished.	
PERFORMANCE OUTCOME:	The candidate shall demonstrate the ability to deploy and operate an attack line; remove flooring, ceiling, and wall components to expose void spaces without compromising structural integrity; apply water for maximum effectiveness; expose and extinguish hidden fires in walls, ceilings, and subfloor spaces; recognize and preserve obvious signs of area of origin and arson; and evaluate for complete extinguishment. Safety: A safety violation is grounds for automatic failure. All proctors present shall review the safety violation.	
Equipment Required: Full PPE including SCBA, pike poles, hand tools, thermal imager (if available), attack line and/or portable water extinguisher.		
Conditions: Given a simulated fire scenario, the candidate shall demonstrate the ability to:		
No.	Task Steps	✓
1.	Select proper equipment and extinguishing source for type of overhaul requested.	
2.	Demonstrate locating hidden fires by sight, touch, sound, or electronic sensor.	
3.	Expose hidden fires in ceilings, walls, and/or subfloor spaces.	
4.	Remove or extinguish burning objects.	
5.	Preserve evidence or signs of cause and origin.	
6.	Ensure and evaluate debris piles or burning material is completely extinguished.	

Evaluator (Print & Sign)

Date:



FIRE FIGHTER I

JPR: FFI-3M

Candidate: _____

STANDARD: 4.3.14 NFPA 1001, 2019 Edition Fire Ground Operations	TASK: Conserve property as a member of a team, given salvage tools and equipment and an assignment, so that the building and its contents are protected from further damage.	
PERFORMANCE OUTCOME: The candidate, while operating as a member of a team, shall demonstrate the ability to cluster furniture; deploy covering materials; roll and fold salvage covers for reuse; construct water chutes and catch-alls; remove water; cover building openings, including doors, windows, floor openings, and roof openings; separate, remove, and relocate charred materials to a safe location while protecting the area of origin for cause determination; stop the flow of water from a sprinkler with sprinkler wedges or stoppers; and operate a main control valve on an automatic sprinkler system.		
Safety: A safety violation is grounds for automatic failure. All proctors present shall review the safety violation.		
Equipment Required: PPE, SCBA, pike poles, salvage covers, and sprinkler wedges or stoppers.		
Conditions: Given a simulated fire scenario and a team, the candidate shall demonstrate the ability to:		
No.	Task Steps	✓
1.	Arrange furnishings in close piles(s) and raised off the floor if possible while preserving evidence or signs of cause and origin.	<input type="checkbox"/>
2.	Cover the pile with a salvage cover using two different spreads. (Check)	<input type="checkbox"/>
	One Firefighter Spread <input type="checkbox"/> Two Firefighter Spread <input type="checkbox"/> Two Firefighter Balloon Throw <input type="checkbox"/>	<input type="checkbox"/>
3.	Construct or perform one of the below called for in the scenario. (Check)	<input type="checkbox"/>
	Water Catch-All <input type="checkbox"/> Water Chute <input type="checkbox"/>	<input type="checkbox"/>
4.	Verbalize OR demonstrate one of the below. (Check)	<input type="checkbox"/>
	Stop Activated Sprinkler Head <input type="checkbox"/> Operate Main Control Valve <input type="checkbox"/>	<input type="checkbox"/>
5.	Roll and/or Fold salvage cover for reuse.	<input type="checkbox"/>

Evaluator (Print & Sign)

Date:



FIRE FIGHTER I

JPR: FFI-30

Candidate: _____

STANDARD: 4.3.16 NFPA 1001, 2019 Edition Fire Ground Operations	TASK: Extinguish incipient Class A, Class B, and Class C fires, given a selection of portable extinguishers, so that the correct extinguisher is chosen, the fire is completely extinguished, and correct extinguisher-handling techniques are followed.	
PERFORMANCE OUTCOME:	The candidate shall demonstrate the ability to operate portable fire extinguishers, approach fire with portable fire extinguishers, select an appropriate extinguisher based on the size and type of fire, and safely carry portable fire extinguishers. Safety: A safety violation is grounds for automatic failure. All proctors present shall review the safety violation.	
Equipment Required: Full PPE if applicable, a variety of fire extinguishers, burn pan or prop.		
Conditions: Given a small Class A, Class B, or Class C fire, and in full protective equipment, the candidate shall demonstrate the ability to:		
No.	Task Steps	✓
CHECK CLASS OF FIRE TO BE EXTINGUISHED: Class A <input type="checkbox"/> Class B <input type="checkbox"/> Class C <input type="checkbox"/>		
1.	Correctly identify the class of fire.	
2.	Select an extinguisher suitable for fire given.	
3.	Properly activate the extinguisher (pull pin and/or puncture cartridge).	
4.	Approach to an effective distance for discharge of the selected extinguisher.	
5.	Discharge extinguisher agent on the base of the fire and sweep over the fire area.	
6.	Advance on the remaining burning material while continuing to extinguish hot spots.	
7.	Extinguish the fire and check for remaining hot spots.	

Evaluator (Print & Sign)

Date:



FIRE FIGHTER I

JPR: FFI-3S

Candidate: _____

<p>STANDARD: 4.3.21</p> <p>NFPA 1001, 2019 Edition</p> <p>Fire Ground Operations</p>	<p>Task: Operate an air-monitoring instrument, given an air monitor and an assignment or task, so that the device is operated and fire fighter recognizes the high- or low-level alarms of the air monitor and takes action to mitigate the hazard.</p>	
<p>PERFORMANCE OUTCOME: The candidate, while operating as a member of a team, shall demonstrate the ability to operate the air monitor, recognize the alarms, and react to the alarms of the air monitor.</p> <p>Safety: A safety violation is grounds for automatic failure. All proctors present shall review the safety violation.</p>		
<p>Equipment Required: Appropriate PPE, Air Monitor.</p>		
<p>CONDITIONS: Given a simulated incident/scenario and a team, the candidate shall demonstrate the ability to:</p>		
No.	Task Steps	✓
1.	Describe operation of meter or instrument.	<input type="checkbox"/>
2.	Describe what alarm activation indicates.	<input type="checkbox"/>
3.	Describe at what point the instrument will alarm.	<input type="checkbox"/>
4.	Describes the actions taken when an alarm sounds.	<input type="checkbox"/>

Evaluator (Print & Sign)

Date: