



# FIRE FIGHTER I

## JPR: FFI-3F

**Candidate:** \_\_\_\_\_

<p><b>STANDARD: 4.3.6</b></p> <p><b>NFPA 1001, 2019 Edition</b></p> <p><b>Fire Ground Operations</b></p>	<p><b>Task:</b> Set up, mount, ascend, descend, dismount ground ladders, given single and extension ladders, an assignment, and team members if needed, so that hazards are assessed, the ladder is stable, the angle is correct for climbing, extension ladders are extended to the necessary height with the fly locked, the top is placed against a reliable structural component, and the assignment is accomplished.</p>	
<p><b>PERFORMANCE OUTCOME:</b></p>	<p>The candidate shall be able to demonstrate the ability to carry ladders, raise ladders, extend ladders and lock flies, determine that a wall and roof will support the ladder, judge extension ladder height requirements, and place the ladder to avoid obvious hazards, mount, ascend, descend and dismount the ladder.</p> <p><b>Safety: A safety violation is grounds for automatic failure. All proctors present shall review the safety violation.</b></p>	
<p><b>EQUIPMENT REQUIRED:</b> Straight ladder, various sizes of extension ladders, and full personal protective clothing (SCBA determined by proctor).</p>		
<p><b>CONDITIONS:</b> Given a simulated fire scenario and a team, the candidate shall demonstrate the ability to:</p>		
<p>No.</p>	<p style="text-align: center;"><b>Task Steps</b></p>	<p>✓</p>
1.	Select the proper length ladder for the designated task.	<input type="checkbox"/>
2.	Lift/carry the ladder from the designated area or apparatus.	<input type="checkbox"/>
3.	Visually check work area for hazards and state if area is safe or if hazards exist.	<input type="checkbox"/>
4.	Raise the ladder upright.	<input type="checkbox"/>
5.	Extend and secure fly section (if using an extension ladder).	<input type="checkbox"/>
6.	Lower ladder against stable wall or surface.	<input type="checkbox"/>
7.	Adjust for proper climbing angle.	<input type="checkbox"/>
8.	Position ladder correctly for task given.	<input type="checkbox"/>



# FIRE FIGHTER I

## JPR: FFI-3I

**Candidate:** \_\_\_\_\_

<p><b>STANDARD: 4.3.9</b></p> <p><b>NFPA 1001, 2019 Edition</b></p> <p><b>Fire Ground Operations</b></p>	<p><b>TASK:</b> Conduct a search and rescue in a structure operating as a member of a team, given an assignment, obscured vision conditions, personal protective equipment, a flashlight, forcible entry tools, hose lines, and ladders when necessary, so that ladders are correctly placed when used, all assigned areas are searched, all victims are located and removed, team integrity is maintained, and team member’s safety – including respiratory protection – is not compromised.</p>	
<p><b>PERFORMANCE OUTCOME:</b></p>	<p>The candidate shall demonstrate to the ability to use an SCBA to exit through restricted passages, set up and use different types of ladders for various types of rescue operations, rescue a firefighter with functioning respiratory protection, rescue a firefighter whose respiratory protection is not functioning, rescue a person who has no respiratory protection, and assess areas to determine tenability.</p> <p><b>Safety: A safety violation is grounds for automatic failure. All proctors present shall review the safety violation.</b></p>	
<p><b>Equipment Required:</b> Full personal protective clothing including SCBA, various size ladders, portable radio, flashlight, hose line, and hand tools.</p>		
<p><b>Conditions:</b> Given a simulated scenario with obscured visibility and a team member, the candidate shall demonstrate the ability to:</p>		
No.	<b>Task Steps</b>	✓
1.	Size up the problem and select the appropriate tool(s) and equipment.	<input type="checkbox"/>
2.	Ladders are correctly placed for assignment (if chosen by candidate).	<input type="checkbox"/>
3.	Establish, maintain, and search in an effective pattern (i.e. left-hand or right-hand).	<input type="checkbox"/>
4.	Maintain team integrity and safety.	<input type="checkbox"/>
5.	Use hose line effectively (if chosen by candidate).	<input type="checkbox"/>
6.	<p><b>Find and remove victim (Check victim chosen).</b></p> <p>Person without respiratory protection <input type="checkbox"/>      Firefighter with Non-Functioning SCBA <input type="checkbox"/>      Firefighter with Functioning SCBA <input type="checkbox"/></p>	

\_\_\_\_\_  
**Evaluator (Print & Sign)**

\_\_\_\_\_  
**Date:**